

# Air Monitoring Certificate



Clearsafe Environmental Solutions Pty Ltd  
 9 Industrial Road, Unanderra NSW 2526  
 info@clearsafe.com.au  
 1300 042 962

**Report Number:** 40-15092-26-AM  
**Monitoring Date:** 9/12/2022  
**Received Date:** 9/12/2022  
**Analysis Date:** 13/12/2022  
**Report Date:** 14/12/2022  
**Site Address:** 307-327R Fitzgerald Avenue  
 Maroubra NSW 2035

**Client Contact:** Blain Knox  
**Sampled By:** Steven Gomes  
**Approved Counter:** Keanen Richardson  
**Approved Signatory:** Luke Heckenberg

**Client Name:** Noble Works Australia Pty Ltd  
**Client Address:** 47 George St  
 Clyde NSW 2142

**Test Method:** Airborne fibre monitoring in accordance with the Guidance Note on the Membrane Filter Method for Estimating Airborne Asbestos Fibres [NOHSC:3003(2005)] and Clearsafe method SOP.AM.01.

**Notes:** The results contained within this report relate only to the samples tested. This report should not be copied, presented or reviewed except in full.

Sample Number	Location	Code*	Time		Airflow		Fibres	Fields	Conc.**
			On	Off	On	Off			
40-15092/148	North western corner of site	5	08:55	15:00	1.99	1.99	0	100	<0.01
40-15092/149	North eastern corner of site	5	08:56	15:01	1.99	1.99	0	100	<0.01
40-15092/150	South western corner of site	5	09:00	15:02	1.99	1.99	0	100	<0.01
40-15092/151	South eastern corner of site	5	09:01	15:03	1.99	1.99	0	100	<0.01
40-15092/152	Field Blank	6					0	100	N/A

\*\* Concentration in Fibres/mL of air

\* Sample Codes:

- 1 - Asbestos removal
- 2 - Bag-out
- 3 - Enclosure dismantling
- 4 - Clearance
- 5 - Background
- 6 - Blank Sample
- 7 - Fibre Count Only
- 8 - Personal monitoring

40-15092-26-AM



**NATA Accredited Laboratory No. 18542**

Accredited for compliance with ISO/IEC 17025 - Testing. The results of the tests, calibrations and/or measurements included in this document are traceable to Australian / national standards.