

Air Monitoring Certificate



Clearsafe Environmental Solutions Pty Ltd
 9 Industrial Road, Unanderra NSW 2526
 info@clearsafe.com.au
 1300 042 962

Report Number: 40-15092-29-AM
Monitoring Date: 14/12/2022
Received Date: 14/12/2022
Analysis Date: 19/12/2022
Report Date: 19/12/2022
Site Address: 307-327R Fitzgerald Avenue
 Maroubra NSW 2035

Client Contact: Blain Knox
Sampled By: Jonathan Eagle
Approved Counter: Nathan Crouch
Approved Signatory: Luke Heckenberg

Client Name: Noble Works Australia Pty Ltd
Client Address: 47 George St
 Clyde NSW 2142

Test Method: Airborne fibre monitoring in accordance with the Guidance Note on the Membrane Filter Method for Estimating Airborne Asbestos Fibres [NOHSC:3003(2005)] and Clearsafe method SOP.AM.01.

Notes: The results contained within this report relate only to the samples tested. This report should not be copied, presented or reviewed except in full.

Sample Number	Location	Code*	Time		Airflow		Fibres	Fields	Conc.**
			On	Off	On	Off			
40-15092/163	North western corner of site	5	07:09	15:30	0.99	0.99	0	100	<0.01
40-15092/164	North eastern corner of site	5	07:10	15:31	0.99	0.99	0	100	<0.01
40-15092/165	South western corner of site	5	07:11	15:32	0.99	0.99	0	100	<0.01
40-15092/166	South eastern corner of site	5	07:12	15:33	0.99	0.99	2	100	<0.01
40-15092/167	Field Blank	6					0	100	N/A

** Concentration in Fibres/mL of air

* Sample Codes:

- 1 - Asbestos removal
- 2 - Bag-out
- 3 - Enclosure dismantling
- 4 - Clearance
- 5 - Background
- 6 - Blank Sample
- 7 - Fibre Count Only
- 8 - Personal monitoring

40-15092-29-AM



NATA Accredited Laboratory No. 18542

Accredited for compliance with ISO/IEC 17025 - Testing. The results of the tests, calibrations and/or measurements included in this document are traceable to Australian / national standards.