

# Air Monitoring Certificate



Clearsafe Environmental Solutions Pty Ltd  
 9 Industrial Road, Unanderra NSW 2526  
 info@clearsafe.com.au  
 1300 042 962

**Report Number:** 40-15092-13-AM  
**Monitoring Date:** 17/11/2022  
**Received Date:** 17/11/2022  
**Analysis Date:** 17/11/2022  
**Report Date:** 18/11/2022  
**Site Address:** 307-327R Fitzgerald Avenue  
 Maroubra NSW 2035

**Client Contact:** Blain Knox  
**Sampled By:** Gonzalo Serna Diaz  
**Approved Counter:** Keanen Richardson  
**Approved Signatory:** Luke Heckenberg

**Client Name:** Noble Works Australia Pty Ltd  
**Client Address:** 47 George St  
 Clyde NSW 2142

**Test Method:** Airborne fibre monitoring in accordance with the Guidance Note on the Membrane Filter Method for Estimating Airborne Asbestos Fibres [NOHSC:3003(2005)] and Clearsafe method SOP.AM.01.

**Notes:** The results contained within this report relate only to the samples tested. This report should not be copied, presented or reviewed except in full.

| Sample Number | Location                | Code* | Time  |       | Airflow |      | Fibres | Fields | Conc.** |
|---------------|-------------------------|-------|-------|-------|---------|------|--------|--------|---------|
|               |                         |       | On    | Off   | On      | Off  |        |        |         |
| 40-15092/69   | Western boundary fence  | 1     | 07:00 | 15:00 | 1.01    | 1.01 | 0      | 100    | <0.01   |
| 40-15092/70   | Northern boundary fence | 1     | 07:03 | 15:03 | 1.01    | 1.01 | 0      | 100    | <0.01   |
| 40-15092/71   | Eastern boundary fence  | 1     | 07:05 | 15:06 | 1.01    | 1.01 | 0      | 100    | <0.01   |
| 40-15092/72   | Southern boundary fence | 1     | 07:07 | 15:09 | 1.01    | 1.01 | 0      | 100    | <0.01   |
| 40-15092/73   | Field Blank             | 6     |       |       |         |      | 0      | 100    | N/A     |

\*\* Concentration in Fibres/mL of air

\* Sample Codes:

- 1 - Asbestos removal
- 2 - Bag-out
- 3 - Enclosure dismantling
- 4 - Clearance
- 5 - Background
- 6 - Blank Sample
- 7 - Fibre Count Only
- 8 - Personal monitoring

40-15092-13-AM



**NATA Accredited Laboratory No. 18542**

Accredited for compliance with ISO/IEC 17025 - Testing. The results of the tests, calibrations and/or measurements included in this document are traceable to Australian / national standards.